

# NEKOOSA



May 7, 2019

Dear Valued Customer,

This letter serves the document which states that VinylEfx Durable passes ASTM E84-11a (Standard Test Method for Surface Burning Characteristics of Building Materials) and falls under classification "A" concluded by lab evaluations completed by Architectural Laboratory on June 20, 2012. No changes to the product have been made since the testing was conducted.

### Actual Data Summary of ASTM E84-11a

Classification	Flame Spread Index	Smoke Developed Index
A	20	25

### ASTM Classified Category

Classification	Flame Spread Index	Smoke Developed Index
A	0-25	0-450
B	26-75	0-450
C	76-200	0-450

If you have any questions or require any additional information, please feel free to contact us at [orders@rtape.com](mailto:orders@rtape.com).

Sincerely,

Cristina Najemian  
Product Development Manager  
RTape Corporation